

School Name: Voorheesville Elementary School								
Lab ELAP id#: 10709					Method of analysis: CP/MS - EPA 200.8 REV 5.4			
Lab ID#	School sample id	collection date	Sample location	Outlet description	Initial/post remediation	Lead result ug/L (ppb)	lab report receipt date	Action Taken
210412008-001	VCSD-VES-05	4/6/2021	3rd Floor Girl's Bathroom	Sink (R)	Initial	1.2	4/15/2021	N/A
210412008-002	VCSD-VES-06	4/6/2021	3rd Floor Girl's Bathroom	Sink (L)	Initial	Not detected (<1)	4/15/2021	N/A
210412008-003	VCSD-VES-07	4/6/2021	3rd Floor Boy's Bathroom	Sink (R)	Initial	Not detected (<1)	4/15/2021	N/A
210412008-004	VCSD-VES-08	4/6/2021	3rd Floor Boy's Bathroom	Sink (L)	Initial	Not detected (<1)	4/15/2021	N/A
210412008-005	VCSD-VES-09	4/6/2021	Classroom 304	Sink	Initial	5.5	4/15/2021	N/A
210412008-006	VCSD-VES-10	4/6/2021	Classroom 226	Fountain	Initial	1.1	4/15/2021	N/A
210412008-007	VCSD-VES-11	4/6/2021	Classroom 226	Sink	Initial	2.6	4/15/2021	N/A
210412008-008	VCSD-VES-12	4/6/2021	Classroom 225	Fountain	Initial	1	4/15/2021	N/A
210412008-009	VCSD-VES-13	4/6/2021	Classroom 225	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-010	VCSD-VES-14	4/6/2021	Classroom 224	Fountain	Initial	4.6	4/15/2021	N/A
210412008-011	VCSD-VES-15	4/6/2021	Classroom 224	Sink	Initial	1.8	4/15/2021	N/A
210412008-012	VCSD-VES-16	4/6/2021	Classroom 223	Fountain	Initial	2.1	4/15/2021	N/A
210412008-013	VCSD-VES-17	4/6/2021	Classroom 223	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-014	VCSD-VES-18	4/6/2021	Classroom 222	Fountain	Initial	3.8	4/15/2021	N/A
210412008-015	VCSD-VES-19	4/6/2021	Classroom 222	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-016	VCSD-VES-20	4/6/2021	Classroom 221	Fountain	Initial	4	4/15/2021	N/A
210412008-017	VCSD-VES-21	4/6/2021	Classroom 221	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-018	VCSD-VES-22	4/6/2021	Classroom 220	Fountain	Initial	3	4/15/2021	N/A
210412008-019	VCSD-VES-23	4/6/2021	Classroom 220	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-020	VCSD-VES-24	4/6/2021	Classroom 219	Fountain	Initial	1.5	4/15/2021	N/A
210412008-021	VCSD-VES-25	4/6/2021	Classroom 219	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-022	VCSD-VES-26	4/6/2021	Classroom 218	Fountain	Initial	Not detected (<1)	4/15/2021	N/A
210412008-023	VCSD-VES-27	4/6/2021	Classroom 218	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-024	VCSD-VES-28	4/6/2021	Classroom 217	Sink	Initial	2.3	4/15/2021	N/A
210412008-025	VCSD-VES-29	4/6/2021	(216C) Girl's Bathroom	Sink (R)	Initial	2.6	4/15/2021	N/A
210412008-026	VCSD-VES-30	4/6/2021	(216C) Girl's Bathroom	Sink (M)	Initial	1.1	4/15/2021	N/A
210412008-027	VCSD-VES-31	4/6/2021	(216C) Girl's Bathroom	Sink (L)	Initial	Not detected (<1)	4/15/2021	N/A
210412008-028	VCSD-VES-32	4/6/2021	Handcap Bathroom	Sink	Initial	Not detected (<1)	4/15/2021	N/A

210412008-029	VCSD-VES-33	4/6/2021	(216B) Boy's Bathroom	Sink (R)	Initial	1.2	4/15/2021	N/A
210412008-030	VCSD-VES-34	4/6/2021	(216B) Boy's Bathroom	Sink (M)	Initial	1.1	4/15/2021	N/A
210412008-031	VCSD-VES-35	4/6/2021	(216B) Boy's Bathroom	Sink (L)	Initial	1.1	4/15/2021	N/A
210412008-032	VCSD-VES-36	4/6/2021	2nd Floor Library	Sink	Initial	1.4	4/15/2021	N/A
210412008-033	VCSD-VES-37	4/6/2021	Nurse's Office Bathroom	Sink	Initial	4	4/15/2021	N/A
210412008-034	VCSD-VES-38	4/6/2021	Nurses Office	Sink	Initial	5.5	4/15/2021	N/A
210412008-035	VCSD-VES-39	4/6/2021	Main Office Bathroom	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-036	VCSD-VES-40	4/6/2021	Bathroom by Room 206	Sink	Initial	2.2	4/15/2021	N/A
210412008-037	VCSD-VES-42	4/6/2021	(204D) Girl's Bathroom	Sink (R)	Initial	Not detected (<1)	4/15/2021	N/A
210412008-038	VCSD-VES-43	4/6/2021	(204D) Girl's Bathroom	Sink (L)	Initial	Not detected (<1)	4/15/2021	N/A
210412008-039	VCSD-VES-44	4/6/2021	Corridor by 204D	Fountain	Initial	Not detected (<1)	4/15/2021	N/A
210412008-040	VCSD-VES-45	4/6/2021	Corridor by 204D	Bottle Filler	Initial	Not detected (<1)	4/15/2021	N/A
210412008-041	VCSD-VES-46	4/6/2021	(204B) Boy's Bathroom	Sink (R)	Initial	1.5	4/15/2021	N/A
210412008-042	VCSD-VES-47	4/6/2021	(204B) Boy's Bathroom	Sink (L)	Initial	1.3	4/15/2021	N/A
210412008-043	VCSD-VES-48	4/6/2021	(204) Faculty Room	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-044	VCSD-VES-50	4/6/2021	Lower Gym Girl's Bathroom	Sink (R)	Initial	1.6	4/15/2021	N/A
210412008-045	VCSD-VES-51	4/6/2021	Lower Gym Girl's Bathroom	Sink (L)	Initial	1.2	4/15/2021	N/A
210412008-046	VCSD-VES-52	4/6/2021	Lower Gym Boy's Bathroom	Sink	Initial	1.1	4/15/2021	N/A
210412008-047	VCSD-VES-53	4/6/2021	Lower Gym	Fountain	Initial	2.8	4/15/2021	N/A
210412008-048	VCSD-VES-54	4/6/2021	Classroom 123	Fountain	Initial	2.1	4/15/2021	N/A
210412008-049	VCSD-VES-55	4/6/2021	Classroom 123	Sink	Initial	1.6	4/15/2021	N/A
210412008-050	VCSD-VES-56	4/6/2021	Classroom 122	Fountain	Initial	Not detected (<1)	4/15/2021	N/A
210412008-051	VCSD-VES-57	4/6/2021	Classroom 122	Sink	Initial	1	4/15/2021	N/A
210412008-052	VCSD-VES-58	4/6/2021	Classroom 121	Fountain	Initial	3.4	4/15/2021	N/A
210412008-053	VCSD-VES-59	4/6/2021	Classroom 121	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-054	VCSD-VES-60	4/6/2021	Classroom 119	Fountain	Initial	3.9	4/15/2021	N/A
210412008-055	VCSD-VES-61	4/6/2021	Classroom 119	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-056	VCSD-VES-62	4/6/2021	Classroom 120	Fountain	Initial	1.5	4/15/2021	N/A

210412008-057	VCSD-VES-63	4/6/2021	Classroom 120	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-058	VCSD-VES-64	4/6/2021	Classroom 118	Fountain	Initial	2.6	4/15/2021	N/A
210412008-059	VCSD-VES-65	4/6/2021	Classroom 118	Sink	Initial	1.5	4/15/2021	N/A
210412008-060	VCSD-VES-66	4/6/2021	Classroom 117	Fountain	Initial	1.2	4/15/2021	N/A
210412008-061	VCSD-VES-67	4/6/2021	Classroom 117	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-062	VCSD-VES-68	4/6/2021	Classroom 116	Fountain	Initial	3.2	4/15/2021	N/A
210412008-063	VCSD-VES-69	4/6/2021	Classroom 116	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-064	VCSD-VES-70	4/6/2021	Classroom 114	Fountain	Initial	Not detected (<1)	4/15/2021	N/A
210412008-065	VCSD-VES-72	4/6/2021	Classroom 114	Sink	Initial	2.6	4/15/2021	N/A
210412008-066	VCSD-VES-73	4/6/2021	Transportation Bathroom	Sink	Initial	2.9	4/15/2021	N/A
210412008-067	VCSD-VES-74	4/6/2021	Transportation Office	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-068	VCSD-VES-76	4/6/2021	(112A) Boy's Bathroom	Sink	Initial	1.8	4/15/2021	N/A
210412008-069	VCSD-VES-77	4/6/2021	(112B) Girl's Bathroom	Sink	Initial	3.9	4/15/2021	N/A
210412008-070	VCSD-VES-78	4/6/2021	(106) Boy's Locker Room	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-071	VCSD-VES-79	4/6/2021	(106) Boy's Locker Room	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-072	VCSD-VES-80	4/6/2021	Outside 3rd Floor Girl's Room	Bottle Filler	Initial	Not detected (<1)	4/15/2021	N/A
210412008-073	VCSD-VES-81	4/6/2021	Outside 3rd Floor Girl's Room	Fountain	Initial	Not detected (<1)	4/15/2021	N/A
210412008-074	VCSD-VES-82	4/6/2021	(105) Girl's Locker Room	Sink (L)	Initial	Not detected (<1)	4/15/2021	N/A
210412008-075	VCSD-VES-83	4/6/2021	(105) Girl's Locker Room	Sink (R)	Initial	Not detected (<1)	4/15/2021	N/A
210412008-076	VCSD-VES-84	4/6/2021	Outside Boy's Locker Room	Fountain	Initial	Not detected (<1)	4/15/2021	N/A
210412008-077	VCSD-VES-85	4/6/2021	Outside Boy's Locker Room	Bottle Filler	Initial	Not detected (<1)	4/15/2021	N/A
210412008-078	VCSD-VES-86	4/6/2021	Kitchen	Sink	Initial	Not detected (<1)	4/15/2021	N/A
210412008-079	VCSD-VES-87	4/6/2021	Garage	Sink	Initial	8.4	4/15/2021	N/A