

| School Name: Voorheesville Middle School | | | | | | | | |
|--|------------------|-----------------|-----------------------|---------------------|--|------------------------|-------------------------|----------------|
| Lab ELAP id#: 10709 | | | | | Method of analysis: ICP/MS - EPA 200.8 REV 5.4 | | | |
| Lab ID# | School sample id | collection date | Sample location | Outlet description | Initial/post remediation | Lead result ug/L (ppb) | lab report receipt date | Action Taken |
| 210412006-001 | VCSD-VMS-01 | 4/6/2021 | Near Faculty Room | Fountain | Initial | Not Detected (<1) | 4/16/2021 | N/A |
| 210412006-002 | VCSD-VMS-02 | 4/6/2021 | Near Faculty Room | Bottle Filler | Initial | Not Detected (<1) | 4/16/2021 | N/A |
| 210412006-003 | VCSD-VMS-03 | 4/6/2021 | Room 200 - Bathroom | Sink (L) | Initial | Not Detected (<1) | 4/16/2021 | N/A |
| 210412006-004 | VCSD-VMS-04 | 4/6/2021 | Room 200 - Bathroom | Sink (ML) | Initial | 1.1 | 4/16/2021 | N/A |
| 210412006-005 | VCSD-VMS-05 | 4/6/2021 | Room 200 - Bathroom | Sink (MR) | Initial | 4.4 | 4/16/2021 | N/A |
| 210412006-006 | VCSD-VMS-06 | 4/6/2021 | Room 202 - Bathroom | Sink (L) | Initial | Not Detected (<1) | 4/16/2021 | N/A |
| 210412006-007 | VCSD-VMS-07 | 4/6/2021 | Room 202 - Bathroom | Sink (ML) | Initial | 4.2 | 4/16/2021 | N/A |
| 210412006-008 | VCSD-VMS-08 | 4/6/2021 | Room 202 - Bathroom | Sink (MR) | Initial | 1.5 | 4/16/2021 | N/A |
| 210412006-009 | VCSD-VMS-09 | 4/6/2021 | Room 203 - Bathroom | Sink | Initial | 1.3 | 4/16/2021 | N/A |
| 210412006-010 | VCSD-VMS-10 | 4/6/2021 | Room 203 - Bathroom | Sink (L) | Initial | Not Detected (<1) | 4/16/2021 | N/A |
| 210412006-011 | VCSD-VMS-11 | 4/6/2021 | Room 203 - Bathroom | Sink (R) | Initial | Not Detected (<1) | 4/16/2021 | N/A |
| 210412006-012 | VCSD-VMS-12 | 4/6/2021 | Room 215 - Kitchen | Sink | Initial | 1.6 | 4/16/2021 | N/A |
| 210412006-013 | VCSD-VMS-13 | 4/6/2021 | Room 215 - Bathroom | Sink | Initial | 1 | 4/16/2021 | N/A |
| 210412006-014 | VCSD-VMS-14 | 4/6/2021 | Room 216 - Classroom | Sink (Front Island) | Initial | 28.3 | 4/16/2021 | Signage Posted |
| 210412006-015 | VCSD-VMS-15 | 4/6/2021 | Room 216 - Classroom | Sink (Rear Counter) | Initial | 16.6 | 4/16/2021 | Signage Posted |
| 210412006-016 | VCSD-VMS-16 | 4/6/2021 | Room 216A - Prep Room | Sink | Initial | 6.7 | 4/16/2021 | N/A |
| 210412006-017 | VCSD-VMS-17 | 4/6/2021 | Room 218 - Classroom | Sink (Front Island) | Initial | 28.6 | 4/16/2021 | Signage Posted |
| 210412006-018 | VCSD-VMS-18 | 4/6/2021 | Room 218 - Classroom | Sink (Rear Counter) | Initial | 13.9 | 4/16/2021 | N/A |
| 210412006-019 | VCSD-VMS-19 | 4/6/2021 | Room 225 - Classroom | Sink | Initial | 1.5 | 4/16/2021 | N/A |

| | | | | | | | | |
|----------------------|-------------|----------|-------------------------------|----------|---------|-------------------|-----------|-----|
| 210412006-020 | VCSD-VMS-20 | 4/6/2021 | Room 227 - Classroom | Sink | Initial | 1.8 | 4/16/2021 | N/A |
| 210412006-021 | VCSD-VMS-21 | 4/6/2021 | Room 200 - Girl's Bathroom | Sink (R) | Initial | Not Detected (<1) | 4/16/2021 | N/A |
| 210412006-022 | VCSD-VMS-22 | 4/6/2021 | Room 200 - Boy's Bathroom | Sink (R) | Initial | Not Detected (<1) | 4/16/2021 | N/A |