

School Name: Voorheesville Middle School								
Lab ELAP id#: 10709					Method of analysis: ICP/MS - EPA 200.8 REV 5.4			
Lab ID#	School sample id	collection date	Sample location	Outlet description	Initial/post remediation	Lead result ug/L (ppb)	lab report receipt date	Action Taken
210412006-001	VCSD-VMS-01	4/6/2021	Near Faculty Room	Fountain	Initial	Not Detected (<1)	4/16/2021	N/A
210412006-002	VCSD-VMS-02	4/6/2021	Near Faculty Room	Bottle Filler	Initial	Not Detected (<1)	4/16/2021	N/A
210412006-003	VCSD-VMS-03	4/6/2021	Room 200 - Bathroom	Sink (L)	Initial	Not Detected (<1)	4/16/2021	N/A
210412006-004	VCSD-VMS-04	4/6/2021	Room 200 - Bathroom	Sink (ML)	Initial	1.1	4/16/2021	N/A
210412006-005	VCSD-VMS-05	4/6/2021	Room 200 - Bathroom	Sink (MR)	Initial	4.4	4/16/2021	N/A
210412006-006	VCSD-VMS-06	4/6/2021	Room 202 - Bathroom	Sink (L)	Initial	Not Detected (<1)	4/16/2021	N/A
210412006-007	VCSD-VMS-07	4/6/2021	Room 202 - Bathroom	Sink (ML)	Initial	4.2	4/16/2021	N/A
210412006-008	VCSD-VMS-08	4/6/2021	Room 202 - Bathroom	Sink (MR)	Initial	1.5	4/16/2021	N/A
210412006-009	VCSD-VMS-09	4/6/2021	Room 203 - Bathroom	Sink	Initial	1.3	4/16/2021	N/A
210412006-010	VCSD-VMS-10	4/6/2021	Room 203 - Bathroom	Sink (L)	Initial	Not Detected (<1)	4/16/2021	N/A
210412006-011	VCSD-VMS-11	4/6/2021	Room 203 - Bathroom	Sink (R)	Initial	Not Detected (<1)	4/16/2021	N/A
210412006-012	VCSD-VMS-12	4/6/2021	Room 215 - Kitchen	Sink	Initial	1.6	4/16/2021	N/A
210412006-013	VCSD-VMS-13	4/6/2021	Room 215 - Bathroom	Sink	Initial	1	4/16/2021	N/A
210412006-014	VCSD-VMS-14	4/6/2021	Room 216 - Classroom	Sink (Front Island)	Initial	28.3	4/16/2021	Signage Posted
210412006-015	VCSD-VMS-15	4/6/2021	Room 216 - Classroom	Sink (Rear Counter)	Initial	16.6	4/16/2021	Signage Posted
210412006-016	VCSD-VMS-16	4/6/2021	Room 216A - Prep Room	Sink	Initial	6.7	4/16/2021	N/A
210412006-017	VCSD-VMS-17	4/6/2021	Room 218 - Classroom	Sink (Front Island)	Initial	28.6	4/16/2021	Signage Posted
210412006-018	VCSD-VMS-18	4/6/2021	Room 218 - Classroom	Sink (Rear Counter)	Initial	13.9	4/16/2021	N/A
210412006-019	VCSD-VMS-19	4/6/2021	Room 225 - Classroom	Sink	Initial	1.5	4/16/2021	N/A

210412006-020	VCSD-VMS-20	4/6/2021	Room 227 - Classroom	Sink	Initial	1.8	4/16/2021	N/A
210412006-021	VCSD-VMS-21	4/6/2021	Room 200 - Girl's Bathroom	Sink (R)	Initial	Not Detected (<1)	4/16/2021	N/A
210412006-022	VCSD-VMS-22	4/6/2021	Room 200 - Boy's Bathroom	Sink (R)	Initial	Not Detected (<1)	4/16/2021	N/A