

Voorheesville CSD Elementary School Lead Testing Results								
Lab ELAP id#: 10478 Primary Accrediting Body					Method of Analysis: EPA 200.8			
Lab ID#	School Sample ID	Collection Date	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result mcg/L (ppb)	Lap Report Receipt Date	Action taken for outlets Greater than 5mcg/L
70287675001	VES-1	2/16/2024	1ST FLOOR HALL	Drinking Fountain	Initial	<1.0	2/22/2024	
70287675002	VES-1A	2/16/2024	1st Floor Hall	Bottle Filler	Initial	<1.0	2/22/2024	
70287675003	VES-2	2/16/2024	Kitchen	Prep sink	Initial	1.2	2/22/2024	
70287675004	VES-3	2/16/2024	Kitchen	Dishwashing	Initial	1.7	2/22/2024	
70287675005	VES-4	2/16/2024	Classroom 114	Sink	Initial	3.7	2/22/2024	
70287675006	VES-4A	2/16/2024	Classroom 114	Drinking Fountain	Initial	<1.0	2/22/2024	
70287675007	VES- 5	2/16/2024	Classroom 116	Sink	Initial	3	2/22/2024	
70287675008	VES-5A	2/16/2024	Classroom 116	Drinking Fountain	Initial	3.1	2/22/2024	
70287675009	VES-6	2/16/2024	Classroom 117	Sink	Initial	2.9	2/22/2024	
70287675010	VES-6A	2/16/2024	Classroom 117	Drinking Fountain	Initial	1.1	2/22/2024	
70287675011	VES-7	2/16/2024	Classroom 118	Sink	Initial	1.9	2/22/2024	
70287675012	VES-7A	2/16/2024	Classroom 118	Drinking Fountain	Initial	3.1	2/22/2024	
70287675013	VES-8	2/16/2024	Classroom 119	Sink	Initial	3.3	2/22/2024	
70287675014	VES-8A	2/16/2024	Classroom 119	Drinking Fountain	Initial	5.3	2/22/2024	Taken out of Service
70287675015	VES-9	2/16/2024	Classroom 120	Sink	Initial	<1.0	2/22/2024	
70287675016	VES-9A	2/16/2024	Classroom 120	Drinking Fountain	Initial	3.9	2/22/2024	
70287675017	VES-10	2/16/2024	Classroom 121	Sink	Initial	2.9	2/22/2024	
70287675018	VES-10A	2/16/2024	Classroom 121	Drinking Fountain	Initial	6.6	2/22/2024	Taken out of Service
70287675019	VES-11	2/16/2024	Classroom 122	Sink	Initial	1.1	2/22/2024	
70287675020	VES-11A	2/16/2024	Classroom 122	Drinking Fountain	Initial	<1.0	2/22/2024	
70287675021	VES-12	2/16/2024	Classroom 123	Sink	Initial	4.2	2/22/2024	
70287675022	VES - 14	2/16/2024	2nd Floor Hall	Drinking Fountain	Initial	<1.0	2/22/2024	
70287675023	VES-14A	2/16/2024	2nd Floor Hall	Bottle Filler	Initial	<1.0	2/22/2024	
70287675024	VES – 15	2/16/2024	Faculty Room	Sink	Initial	<1.0	2/22/2024	
70287675025	VES- 16	2/16/2024	2nd Floor Hall	Drinking Fountain	Initial	<1.0	2/22/2024	
70287675026	VES – 16A	2/16/2024	2nd Floor Hall	Bottle Filler	Initial	<1.0	2/22/2024	
70287675027	VES - 17	2/16/2024	Nurses Office	Sink	Initial	1.9	2/22/2024	
70287675028	VES - 18	2/16/2024	Nurse Office Bathroom	Sink	Initial	1.3	2/22/2024	
70287675029	VES- 19	2/16/2024	Library Workroom	Sink	Initial	4.3	2/22/2024	
70287675030	VES - 20	2/16/2024	Classroom 217	Sink	Initial	2.8	2/22/2024	
70287675031	VES – 21	2/16/2024	Classroom 218	Sink	Initial	2.6	2/22/2024	
70287675032	VES – 21A	2/16/2024	Classroom 218	Drinking Fountain	Initial	<1.0	2/22/2024	
70287675033	VES – 22	2/16/2024	Classroom 219	Sink	Initial	7.9	2/22/2024	Signage: Do Not Drink
70287675034	VES – 23	2/16/2024	Classroom 220	Sink	Initial	2.1	2/22/2024	
70287675035	VES – 23A	2/16/2024	Classroom 220	Drinking Fountain	Initial	3.6	2/22/2024	
70287675036	VES – 24	2/16/2024	Classroom 221	Sink	Initial	2.8	2/22/2024	
70287675037	VES – 25	2/16/2024	Classroom 222	Sink	Initial	2.7	2/22/2024	
70287675038	VES – 25A	2/16/2024	Classroom 222	Drinking Fountain	Initial	2.5	2/22/2024	
70287675039	VES – 26	2/16/2024	Classroom 223	Sink	Initial	1.8	2/22/2024	
70287675040	VES – 27	2/16/2024	Classroom 224	Sink	Initial	2.8	2/22/2024	
70287675041	VES – 27A	2/16/2024	Classroom 224	Drinking Fountain	Initial	2.9	2/22/2024	

70287675042	VES – 28	2/16/2024	Classroom 225	Sink	Initial	6	2/22/2024	Signage: Do Not Drink
70287675043	VES – 28A	2/16/2024	Classroom 225	Drinking Fountain	Initial	1.2	2/22/2024	
70287675044	VES – 29	2/16/2024	Classroom 226	Sink	Initial	3.5	2/22/2024	
70287675045	VES – 29A	2/16/2024	Classroom 226	Drinking Fountain	Initial	1.3	2/22/2024	
70287675046	VES – 30	2/16/2024	3rd Floor Hall	Drinking Fountain	Initial	<1.0	2/22/2024	
70287675047	VES – 30A	2/16/2024	3rd Floor Hall	Bottle Fill	Initial	<1.0	2/22/2024	